


5' x 10' Heavy Duty (Pump Station) 1,000 - 3,500 Gallon (HD5-10)



Tank Capacity	Inlet (A)	Outlet (B)	Height (C)	Weight
1000 gallon	43"	As Required	62"	21,000 lbs
1250 gallon	50"	As Required	68"	22,200 lbs
1500 gallon	58"	As Required	74"	23,300 lbs
2000 gallon	73"	As Required	92"	26,900 lbs
2500 gallon	89"	As Required	110"	30,400 lbs
3000 gallon	105"	As Required	122"	32,800 lbs
3500 gallon	121"	As Required	138"	36,000 lbs

- SPECIFICATIONS:**
- Concrete Minimum Strength 5000psi @ 28 days
 - Steel Reinforcement Grade 60
 - Joints Sealed with Butyl Sealant
 - Inlet Baffle by Others
 - H2O Loading
 - (*) Denotes Top Seam Construction
 - Weights Subject to Variation



TRUPELL CONSULTING ENGINEERS
478 BLAIR PARK ROAD | WILLISTON, VERMONT 05495
802.879.4331 | WWW.TCEVT.COM

Revisions	No.	Description	Date	By
	1	Final Plan Review	01/23/15	NTH
	2	Local Submittal Edits	03/23/15	NTH

Use of These Drawings
1. Unless otherwise noted, these Drawings are intended for preliminary planning, coordination with other disciplines or utilities, and/or approval from the regulatory authorities. They are not intended as construction drawings unless noted as such.

2. Only drawings specifically marked "For Construction" are intended to be used in conjunction with contract documents, specifications, owner/contractor agreements and to be fully coordinated with other disciplines, including but not limited to the Architect, if applicable. These Drawings shall not be used for construction layout. Contact TCE for any construction surveying services or to obtain electronic data suitable for construction layout.

3. These Drawings are specific to the Project and are not transferable. As instruments of service, these drawings, and copies thereof, furnished by TCE are its exclusive property. Changes to the drawings may only be made by TCE. If errors or omissions are discovered, they shall be brought to the attention of TCE immediately.

4. By use of these drawings for construction of the Project, the Owner represents that they have reviewed, approved, and accepted the drawings and have met with all applicable parties/disciplines to insure these plans are properly coordinated with other aspects of the Project. The Owner and Architect, are responsible for any buildings shown, including an area measured a minimum five (5) feet around any building.

5. It is the User's responsibility to ensure this copy contains the most current revisions.



For Local Permitting Only

Project Title

Jericho Market
364 VT Route 15 Jericho, VT

Sheet Title

Sanitary Details

Date:	10/10/14
Scale:	SHOWN
Project Number:	14-139
Drawn By:	NPC
Project Engineer:	NTH
Approved By:	
Field Book:	

RECEIVED
3/24/15
PeakCM

C8-02